

**SHRI SAIBABA SANSTHAN TRUST, SHIRDI**

SHIRDI Post : Shirdi - 423 109, Tal. Rahata, Dist. Ahmednagar, Maharashtra (India).

Telephone : +91 - 2423 - 258 500, Fax : +91 - 2423 - 258 770, Telegram : Sainath, Shirdi.

No. SSST/Mechanical/ 3427 /2021

Date :- 1 JAN 2022

To,

Sub :- Quotation for purchase of Gas plant spare part with repairing & maintenance and Calibrations of Instruments.

Sir,

We are inviting the quotation for purchase of Gas plant spare part & Calibrations of mounded LP Gas plant Instruments for Shri Saibaba Sansthan Trust Shirdi as per technical Specification and following terms & condition

Sr.No	Description of Material	Qty	Unit	Rate	Amount
<b>A</b>	<b>Material</b>				
1	Pressure gauge with Isolation valve Make- Baumer, Radix, Pointer 4" Dail. SS body Glycerine filled, 1/2" BSP connection, Range (0 to 35 kg/cm <sup>2</sup> )	4	Nos		
2	Pressure gauge with Isolation valve Make- Baumer, Radix, Pointer 4" Dail. SS body Glycerine filled, 1/2" BSP connection, Range (0 to 20 kg/cm <sup>2</sup> )	2	Nos		
3	Pressure gauge with Isolation valve Make- Baumer, Radix, Pointer 6" Dail. SS body Glycerine filled, 1/2" BSP connection, Range (0 to 35 kg/cm <sup>2</sup> )	2	Nos		
4	Pressure gauge with Isolation valve Make- Baumer, Radix, Pointer 2" Dail. SS body Glycerine filled, 1/4" BSP connection, Range (0 to 28 kg/cm <sup>2</sup> )	2	Nos		
5	Temperature gauge Make- Baumer, Radix, Pointer 6" Dail. SS body Glycerine filled, 1/2" BSP connection, Range (-50°C to 70°C)	2	Nos		
6	1" Teflon Gasket 300#	100	Nos		
7	1 1/2" Teflon Gasket 300#	100	Nos		
8	2" Teflon Gasket 300#	100	Nos		
9	600NB Metallic gasket for tank manhole-CS-Out & SS-In	2	Nos		
10	350NB Metallic Gasket for tank manhole	2	Nos		
11	50NB Liquid Unloading Hose 10 Mtr long ACME x FE300#	1	Nos		
12	40NB Vapour Unloading Hose 10 Mtr long ACME x FE300#	1	Nos		
13	50NB ROV Coil with Solenoid Valve Make -Micro Pneumatic, Coil- 230V AC	2	Nos		
14	65NB ROV Coil with Solenoid Valve Make -Micro Pneumatic, Coil- 230V AC	5	Nos		
	Total				
<b>B</b>	<b>Offer for Calibration, Programming And Certification</b>				
1	Calibration of LPG Gas Detectors	8	Nos		
2	Validation and verifying all instruments input from field to the panel	1	Job		
3	Calibration and certification of POP Action valve	1	Job		
	Total				
	GST				
	A + B Total				

Page No. 01



MUMBAI Sainiketan, 804 - B, Dr. Ambedkar Marg, Dadar, Mumbai - 400 014.


Telephone : +91 - 22 - 24166556, Fax : +91 - 22 - 24150798. Telegram : Sainiketan, Mumbai.

website : <http://www.shrisaibabasansthan.org> \* E\_mail : saibaba\_anr@sancharnet.in / saisandesh\_anr@sancharnet.in

## Term & Condition

1. The tenderer firm must be approve Explosive Department, Govt. Of India.
2. The rate should be inclusive of GST, Transportation, Packing & forwarding charges.
3. Spare parts will have be supplied Shirdi.
4. Rate quoted by you will be final
5. No advance payment , in any case would be made . 95% payment will be made after 15 days from the date of completion of work.
6. 5% amount of work order will be refundable after 6 months from the work completion.
7. Time Period :- 3 months from the date of work order.
8. Penalty – for delay a completion of work penalty Rs .200/- per day.
9. After completion of work ( repairing , Calibration ) tenderer should have submit third party (competent authority of PESO) inspection report.
10. The spare parts should be as per specification & no other technical specification of the company will be acceptable.
11. The tenderer shall submit the offer sealed envelope. An envelope should be clearly attached & superscripted as “Mechanical Department - Quotation of Gas plant spare part & Calibrations of Instruments” . Quotation submitted inward office of Sansthan on or before dated 22 / 01 /2022
12. In case of any dispute the same will be subject to the Jurisdiction of the compliant court at Rahata.
13. Shri Saibaba Sansthan Turst Shirdi reserve the right to reject any or all tender / quotation without assigning any reasons there for.

Please send your offer at the earliest.

  
(Sanjay Jori)

I/C Executive Engineer  
Shri Saibaba Sansthan Trust Shirdi