



SHRI SAIBABA SANSTHAN TRUST, SHIRDI

PTR. NO. : E-69, AHMEDNAGAR

SHIRDI : Post : Shirdi - 423 109, Tal. Rahata, Dist. Ahmednagar, Maharashtra (India)
Telephone : +91-2423-258 500, Fax : +91-2423-258 770, Telegram : Sainath, Shirdi.

To,

No. SSST/Fire & Safety/ 3625 /2024

Date :

20 JAN 2025

Subject:- QUOTATION FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF FIRE FIGHTING SYSTEM SUCH AS HOSE REEL DRUM SYSTEM, CONVENTIONAL FIRE DETECTION & ALARM SYSTEM AT - SAINIKETAN, DADAR, MUMBAI.

Dear Sir,

We are inviting the quotation for Supply, Installation, Testing and Commissioning of Firefighting System such as (Hose reel drum system, Conventional fire detection & Alarm system) at Shree Saibaba Sansthan Trust, Shirdi Sai Niketan, 804,-B Dr.Ambedkar Marg, Dadar, Mumbai- 400014. You are requested to submit your quotation in sealed envelope to our Shirdi office on or before on 31/01/2025 upto 17:00 PM address as noted above to The Chief Executive Officer, Shree Saibaba Sansthan Trust, Shirdi.

1. The contractor shall submit the offer containing bid in two sealed envelopes as below –
Envelope No. 01 – Document required for minimum qualifying criteria (The quotation document attached herewith which can also be downloaded from our website www.sai.org.in)
Envelope No. 02 – The Second envelope clearly marked as “Envelope No. 02” shall contain your commercial, offer.
2. Two sealed Envelope No. 01 & 02 shall be again put together in one common envelope & sealed. This sealed envelopes should be superscribed as **Quotation of Supply, Installation, Testing and Commissioning of Firefighting System such as (Hose reel drum system, Conventional fire detection & Alarm system) for Shri Saibaba Sansthan Trust, Shirdi Sainiketan Building, Dadar, Mumbai for Fire & Safety Dept.”**
3. No Advance will be paid by Sansthan.
4. The Rate should be exclusive of GST.
5. The Chief Executive Officer, Shree Saibaba Sansthan Trust, Shirdi reserves the right to reject any OR all quotation without assigning any reason thereof.
6. The details of the fire fighting system, terms conditions & blank quotation form are attached herewith.

Thanking You,

With Blessings of Shri Saibaba...!

(Goraksha Gadilkar, I.A.S.)

Chief Executive Officer,

Shree Saibaba Sansthan Trust, Shirdi.



MUMBAI : Sainiketan, 804, - B, Dr. Ambedkar Marg, Dadar, Mumbai - 400 014
Telephone : + 91-22-24166556, Fax : + 91-22-24150798, Telegram : Sainiketan, Mumbai

• Website : <http://www.shrisaibabasansthan.org> / www.sai.org.in • E_mail : saibaba@sai.org.in



Fire & Safety Department

**QUOTATION FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING
OF FIRE FIGHTING SYSTEM SUCH AS HOSE REEL DRUM SYSTEM,
CONVENTIONAL FIRE DETECTION & ALARM SYSTEM
AT SAINIKETAN, DADAR, MUMBAI.**

SHREE SAIBABA SANSTHAN TRUST, SHIRDI

Po. Shirdi, Tal. Rahata, Dist. Ahmednagar.

Phone No. (02423) - 258981

Website: - www.sai.org.in

Email – fire.safety@sai.org.in



SHREE SAIBABA SANSTHAN TRUST
Fire & Safety Department
Po. Shirdi, Tal. Rahata, Dist. Ahmednagar.
Phone No. (02423) - 258981
Website: - www.sai.org.in
Email- fire.safety@sai.org.in

QUOTATION FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF FIRE FIGHTING SYSTEM SUCH AS HOSE REEL DRUM SYSTEM, CONVENTIONAL FIRE DETECTION & ALARM SYSTEM AT SAINIKETAN, DADAR, MUMBAI.

Sealed Quotations are invited for Supply, Installation, Testing and Commissioning of Firefighting System such as Hose reel drum system, Conventional fire detection & Alarm system. The details will be available on www.sai.org.in for downloading.

• **Time Table for quotation submission :**

Quotation Publish Date	Dt. 29-09-2024	Time- 11.00
Submission Start Date	Dt. 29-09-2024	Time- 11.00
Submission End Date	Dt. 29-09-2024	Time- 17.00

• **Validity Period:**

The offer of the bidder shall remain valid for acceptance for a minimum period of **15 days** from the last date of submission the quotation.

• **Scope of Work.**

- 1) Supply, installation, testing and commissioning of Firefighting System such as Hose reel drum system, Conventional fire detection & Alarm system.
- 2) Provide drawing and operating training to SSST employees.
- 3) Successful quotation holder has to send their technician monthly to inspect, adjust, rectify the System, in warranty period.

- **Security Deposit (SD):** Successful bidder has to deposit **3%** amount of awarded cost as security deposit within 07 days from acceptance of work order. This SD amount will be refunded after warranty period. No interest will be paid on the Security Deposit.

• **Quotation** – Quotation must submit in sealed envelope only with following attachments.

1. Contractor have Registered with Directorate of Maharashtra Fire Services in appropriate class and same need to be attached with Quotation.
2. Certificate of GST Registration and PAN, in the name under which quotation is to be submitted.
3. Quotation specific Authorization letter from manufacture of the makes specified to be produced on the company letter head duly signed by the company Authority.
4. Letter stating that the Firm / Company is not blacklisted by Central / State Government, Government Corporation, statutory Institute. (on firm letter head)
5. Letter on company/Firm letter head Stating that “Company/Firm have read all terms and conditions and agree with them”
6. Fill and attach the ‘Annexure A, B and C.

- **Acceptance of Quotation:**

The bidders shall only have opened and lowest offer (Set wise) amongst the opened bid will be accepted. The acceptance of quotation will be communicated to the quotation by email or otherwise.

- **Payments:**

1. No advance will be given for the said supply.
2. 100% amount of order will be paid after supply, successful Installation / commissioning, Firefighting System
3. Applicable taxes will be deducted at source from bills at the prevailing rate.

- **Penalty:**

1. If the machineries and materials are not supplied and installed as per the supply order within the time limit, liquidated damages are recovered as follows.

If the cost of supply order less than Rs.2.00 lakhs	0.50% per week up to a maximum of 10%
If the cost of supply order is above Rs.2.00 lakhs or more	0.50% per week up to a maximum of 5 %

2. In case supply material is rejected because of it is not as per the supply order or not supply in specified time, the Sansthan shall be allowed to purchase the machinery from the market as per the market price and the excess amount (difference) for such purchased material shall be recovered from the Security Deposit or subsequent Bills.

- **Warranty Period-** Warranty period of Fire System is 1 year from the date of commissioning. Supplier should provide 24 X 7 online supports within warranty period. And should help our representative to log the call with respective company / OEM. If supplier fails to resolve the issue in 48 hours from next business day, Rs.500/- will be deducted per week from security deposit until the issue is resolved.

- **Terms and Conditions:**

1. The quotation should quote rate as per the specification.
2. Contractor should complete work as per specification within 30 days.
3. The bidder should study all the tender documents carefully and understand the quotation contract conditions, specifications etc. before quoting. If there are any doubts, they should get clarifications in writing but this shall not be a justification for submission of late tender or extension of submission date.
4. Rates quoted by tenderer should be including of GST, Mechanical structure, Load cell assembly, Hydra, unloading & fitting facility, Earthing, transport, installation charges.
5. The quotation should not submit documents other than called in quotation.
6. The make, brand model etc. giving details of the items quoted should be mention in the quotation.
7. If you need any more information regarding the specification of quotation materials or quotation , please contact 02423-258981
8. Conditional quotation will be rejected.
9. Shree Saibaba Sansthan Trust reserves the rights to any changes, amendments in the tender or accept / reject partial / Full Quotation.

- **Award of Contract;**- The Sansthan will award the contract to the successful contractor whose quotation has been determined to be substantially responsive and has been determined as lowest evaluated quotation. The Chief Executive Officer, SSST reserve the right to increase or decrease the quantity to be purchased and also reserves the right to cancel or revise or any of the all tenders or part of quotation without giving any reasons.
- **Testing of materials :-** The engineer shall be entitled to have tests carried out as specified in IS for any materials supplied by the quotation at the cost of work order.
- **Delivery Schedule**
 1. Successful quotation should supply the machinery and materials within 1 week from the work order date. quotation should complete the Installation / commissioning / training within 3 weeks from the machinery and materials delivery date. In total, quotation can manage the delivery , supplied and installation, commissioning, training 4 weeks from work order date.
 2. In case of rejection for not confirming/matching as per supply order specification the same will be sole responsibility of the supplier to make arrangement to collect the same at his own cost and risk immediately
 3. Delivery of machinery and materials to be done at 804,-B Dr. Ambedkar Marg, Dadar Mumbai 400014 Sai Niketan, Dadar, Mumbai East on working day between 10 am to 6 pm.
 4. Transport, freight and other charges will be quotation responsibility.
- **Resolution of Disputes-**

In case of any disputes between parties, the jurisdiction shall vest at Rahata court only.



(Goraksha Gadilkar, I.A.S.)

Chief Executive Officer,
Shree Saibaba Sansthan Trust, Shirdi.



ANNEXURE- A

Personal & Bank Details for RTGS
All columns are mandatory
(Submit on Company Letter Head)

Sr. No.	Personal Detail	
1	Name of the Firm	
2	Address	
3	Contact Person and Cell No	
4	GST Number	
5	Bank Details –	
	Name of the Bank	
	Bank City	
	Branch Name and Code	
	Account Type	
	Account Number	
	IFSC CODE	
	MICR NO.	
7	Stamp and Signature of the agency	

Annexure B

Submission Letter (On Bidders letter head)

Date- -----

To,
Chief Executive Officer,
Shree Saibaba Sansthan Trust (Shirdi)
Shirdi, Tal-Rahata, District-Ahmednagar.

Subject:- Supply, Installation, Testing and Commissioning of Firefighting System such as Hose reel drum system, Conventional fire detection & Alarm system for Shree Saibaba Sansthan Trust Shirdi at the branch office at 804-B, Sai Niketan, Dr. Ambedkar Marg, Dadar (East), Mumbai- 400014

Respected Sir,

I / We, the undersigned, declare that we have read the quotation published on www.sai.org.in portal regarding the above subject. I / we have read all the terms and conditions given and I / we agree to abide by your terms / conditions.

I / We undertake to deliver the machinery and materials mentioned in the quotation to the Fire & Safety Department of Shree Saibaba Sansthan Trust, Shirdi as and when required, as per your demand for the above period as per the requirement.

I / We shall deposit 3% Security Deposit immediately after the acceptance of the quotation and it shall be our obligation to **Supply, Installation, Testing and Commissioning of Firefighting System such as Hose reel drum system, Conventional fire detection & Alarm system** to the Shree Saibaba Sansthan Trust Shirdi at 804-B, Sai Niketan, Dr. Ambedkar Marg, Dadar(East), Mumbai-400014 at the approved rate.

Yours / Yours faithfully,

Name of the owner/partner of the firm

Signature and seal

(1) -

(2) -

Accompanying documents

Annexure C

Compliance Sheet for Technical Document

Sr. No.	Tender Requirement.	Attached Documents
1	PAN CARD	
2	Certificate of registration for GST, Company	
3	Letter stating that the Firm / Company is not blacklisted by Central / State Government, Government Corporation, statutory Institute. (On letter head of Firm)	
4	Letter stating that Firm / Company has read all terms & conditions, and agreed with them. (On letter head of Firm)	


BOQ

Name of Tender :- Quotation for Fire Fighting System Supply, Installation, Testing and Commissioning of Firefighting System such as Hose reel drum system, Conventional fire detection & Alarm system at Sai Niketan, Dadar, Mumbai

Sr. No	Material Description	Unit	Qty	Make List	Rate		Amount
					Supply	ITC	
1	<p>Supplying, installation, testing and commissioning of booster fire pump [BP] suitable for water discharge of 450 LPM at 35 m head driven by electric motor 415 volts, 3 phase 50 Hz, AC supply of 5.5 KW or of suitable kW capacity for manual/automatic operation and consisting of following :-</p> <p>(a) Horizontal/vertical type, single/multi stage, centrifugal casing pump of cast iron body & bronze/CI impeller with stainless steel shaft (SS410 grade), mechanical seal conforming to IS 1520.</p> <p>(b) Squirrel cage induction motor, TEFC, synchronous speed 3000 RPM, suitable for operation with IP 55 protection for enclosure, horizontal foot mounted type with Class-'F' insulation, conforming to IS-325.</p> <p>(c) M.S. fabricated common base plate, coupling, coupling guard, foundation bolts etc. as required.</p> <p>(d) Erected on Angle Frame with perfect aligning, proper levelling complete pump set with accessories duly painted with two coats of synthetic enamel paint colour over a coat of primer (ISC code 536 as per IS 2932 of 2003) complete, as per specification no. FF-MFP/BP.</p>	Nos.	1	Kirloskar			
2	Supplying and erecting G.I. pipe 'C' class ERW 25 mm dia with necessary fittings duly painted with two coats of synthetic enamel paint of fire red colour over a coat of primer (as per IS 2932 of 2003) complete as per specification no. FF-PP	Mtrs.	6	Jindal / Appolo			

Sr. No	Material Description	Unit	Qty	Make List	Rate		Amount
					Supply	ITC	
3	Supplying and erecting G.I. pipe 'C' class ERW 75/80 mm dia with necessary fittings duly painted with two coats of synthetic enamel paint of fire red colour over a coat of primer (as per IS 2932 of 2003) complete as per specification no. FF-PP	Mtrs.	50	Jindal / Appolo			
4	Supplying and erecting 75/80 mm dia. cast iron double flange butterfly valve of size complete with PN16 pressure rating, as per specification no. FF-VL/BFV	Nos.	1	Zoloto / Normex / Kartar			
5	Supplying and erecting 100 mm dia. cast iron double flange butterfly valve of size complete with PN16 pressure rating, as per specification no. FF-VL/BFV	Nos.	2	Zoloto / Normex / Kartar			
6	Supplying and erecting 100 mm dia cast iron double flange NRV complete with PN16 pressure rating, as per specification no. FF-VL/NRV	Nos.	1	Zoloto / Normex / Kartar			
7	Supplying and erecting 25 mm Ball Valve complete with PN1 6 pressure rating, as per specification no. FF-VL/BV	Nos.	7	Zoloto / Sant / Kartar			
8	Providing and fixing 50 mm Ball Valve with complete with PN16 pressure rating, as per specification no. FF-VL/BV	Nos.	1	Zoloto / Sant / Kartar			
9	Supplying and installing wall mounting swinging hose reel drum fitted with 19 mm dia. 30m long high pressure polypropylene (Polyhose) along with necessary accessories (Shut up Nozal MOC – Gunmetal) complete as per specification no. FF-FFA/HV	Nos.	4	Fireshield / Armour Fire / Essel Fire			
10	Supplying and erecting 20/25mm dia gunmetal air release cock, with necessary G.I. coupling to be fitted on top of air vessel or on wet riser complete as per specification no. FF-FFA/ARV	Nos.	1	Zoloto / Sant / Kartar			
11	Supplying and erecting 100 mm dia pressure gauge, 0-300 PSI or 0-14kg per cm square fitted with 12/15 mm dia pad cock valve erected with provided G.I. Pipe, elbow etc. complete as per specification no. FF-FFA/PG	Nos.	1	General Instruments / H-Guru			

Sr. No	Material Description	Unit	Qty	Make List	Rate		Amount
					Supply	ITC	
12	Supplying, installing, testing and commissioning FR, XLPE armoured cable 2 core 1.5 sq.mm. Copper conductor complete erected on wall/ ceiling complete as per specification no. CB-LT/CU	Meters	70	ASES / Ravel			
13	Supplying, installing, testing and commissioning of 2 Zone Microprocessor based, conventional fire alarm control panel (FACP) with standard accessories, 16x2 Character LCD Display, provision for zone wise contact and beep sound alarm, suitable to operate on 120-220 V AC, complete as per specification no. FF-FAAS/FACP	Nos.	1	ASES / Ravel			
14	Supplying, erecting & terminating FR XLPE insulated, galvanised steel formed wire armoured (strip) cable, 1100 V 4 core 10 sq. mm. aluminium conductor complete erected with glands & lugs on wall / trusses / pole or laid in provided trench / pipe as per specification no. CB-LT/AL	Meters	32	F&S Firecab			
15	Supplying, erecting, testing and commissioning of automatic control panel for three phase, 415 V, A.C. supply, submersible / centrifugal pump set up to 7.5 HP consisting of D.O.L. starter having relay range 9-14 A, S.P.P., combined ammeter/voltmeter, phase indicating lamp enclosed in CRCA powder coated vibration proof enclosure with IP54 protection with single phasing, phase reversal, phase imbalance, etc.	Nos.	1	Juvik Solutions Pvt Ltd,			
16	Supply, Fabricating and fixing of Fluorescent type Safety Signs and Exit Signs on all Strategic locations as per the IS 123449 & IS 12407	Nos.	5	STD / AutoGlo			


 (Goraksha Gadgilkar, I.A.S.)
Chief Executive Officer,
 Shree Saibaba Sansthan Trust, Shirdi.

